



Increasing the use of DG in the Semiconductor industry

**Distributed Power and Industrial DG
Program Review/Peer Review
January 30, 2002**

INTERNATIONAL
SEMATECH





Technical Project Manager,
Tom Rizy, ORNL

Project Manager,
Barry Cummings, SRP

Strategic Plan for Distributed Energy Resources *

“Document and widely disseminate the findings of the **energy, economic, and environmental** benefits of the expanded use of distributed energy resources”

[of combined DER benefits to large energy users, energy suppliers and energy delivery systems]

*Office of Energy Efficiency and Renewable Energy DOE, september 2000



Comprehensive National Energy Strategy(CNES)



- # Improve efficiency of energy system
- # Ensure against energy disruptions
- # Promote energy production and use respecting health & environmental values
- # Expand future energy choices



Project status related to CNES goals



- # Opportunities limited to new FABs.
- # Public Process Manageable.
- # Unlikely a 'major source' issue
- # Inspections and existing review processes will be challenge.
- # Requires grid connected DER



Increasing DER Opportunities



- # Combining supplier & semiconductor FAB plant benefits
- # Technical and economic changes in the next 5 to 10 years



Objectives



- # A management decision guideline
- # Research tool for site-specific, feasibility studies
- # Identified technical and economic improvements needed

SCOPE & LIMITATIONS

- # Ownership of DER not in scope
- # Contractual and rate issues not in scope:

“Social Economics of Alternatives”

Or

“Is there enough \$’s on the table to bother negotiating?”




Semiconductor wafer fabrication characteristics

- # Energy-intensive process
- # Requires stable electrical power
- # Large production losses from poor power quality
- # Large production losses from power outages



KEY FAB OWNER NEEDS



- # No additional fuel/energy price risk
- # Internal rate of return > 18%
- # Allow 100% factory function with any/all of the DG system shut down
- # Installation not impact factory start-up schedule
- # Factory reliability improved



DER Supplier's needs

- # Economical compared to other generation alternatives
- # DER grid and 'islanded' dispatchable by utility
- # Does not require 'Major Source' air quality permit
- # Highly reliable, i.e. $> 98\%$



Initial forecasts thru 2010




- # Combustion turbines most likely DER for next 5-10 years.
- # Fuel cells may become competitive.
- # # DER “Retrofits” at existing FABS will be Insignificant. [economics, space, operation, external constraints]




Two alternatives: One GE LM 6000 or Two GE LM 2500


	CASE							
	2A	2B	3A	3B	4A	4B	5A	5B
1-GE LM 6000	X	X	X	X				
2-GE LM 2500					X	X	X	X
Cogeneration	X	X	X	X	X	X	X	X
<i>Combined Cycle</i>	X	X			X	X		
<i>Simple Cycle</i>			X	X			X	X
Steam Turbine Chillers	X		X		X		X	
Absorption Chillers		X		X		X		X




Combustion Turbine DER Annualized Cost*



Case 3A – Cogeneration, 45 MW combustion turbine, 140,000 sq ft clean Room



Key Variables Sensitivity – Combustion Turbine



■ Case 3A – Cogeneration, simple cycle 45 MW combustion turbine at 140,000 sq ft

Combustion Turbine DER, ancillary benefits



OPERATIONS

- # Product losses from voltage sags > \$1.5M/yr
- # Delivery system losses reduced > \$400,000/yr

CAPITAL

- # \$2M for one less redundant transmission line
- # \$4M Reduced Diesel back-up generation



Combustion Turbine, DER Site (Case 3) Air Emissions


- # NO_x - 20 tons per year
- # CO - 23 tons per year
- # SO_x - 12 tons per year
- # Particulate matter* - 45 tons per year
- # Volatile organic compounds - 4 tons per year



NOTE: Cogen Simple Cycle Combustion Turbine DER




Global Change in annual gas usage C.T versus Grid supplied gas generator






END





The following are
Back-Up Slides to
respond to questions





Status

Develop DG Guidelines - Complete

Develop Design Concepts - Complete

Determine Potential Markets - 01/02

Identify Key Risk Factors - 01/02

Draft Final Report - 01/02

Review Final Report – 03/02

Alternatives within contract scope

- # Gas Turbines**
 - # Fuel Cells**
 - # Alternative energy sources requiring energy storage**
-

Conceptual Design Scope





DER engineering feasibility design addressing;

- Economics,
- Infrastructure,
- Energy delivery,
- Institutional,
- Regulatory needs.



Sensitivity for key elements







DG comparison

	Combustion Turbines (w/o cogen)	Fuel Cells	Solar PV	Grid combined cycle
Plant Capital Cost, \$/kW	450	4,000	6,500	600
Fixed O&M, \$/kW-yr	20	91.4	17	6
Net Heat Rate, BTU/kWh HHV	10,500	7,500	n/a	7,300
First Year's Cost, Dollars/MWh	54	138	500	51

**1 year total tons of emission change, at
site, DG versus no DG 100% 35k clean
room new plants
(average seven 2002 & 2003 planned new fabs)**




**INDUSTRIAL
DISTRIBUTED
GENERATION**

Energy costs per year

- Energy sales
- Purchase electricity
- Natural gas

Initial cost in millions of dollars



Key Capital Costs

